

HOUSE No. 2821

The Commonwealth of Massachusetts

PRESENTED BY:

John J. Lawn, Jr.

To the Honorable Senate and House of Representatives of the Commonwealth of Massachusetts in General Court assembled:

The undersigned legislators and/or citizens respectfully petition for the adoption of the accompanying bill:

An Act to establish standards for medical gas piping systems.

PETITION OF:

NAME:	DISTRICT/ADDRESS:
<i>John J. Lawn, Jr.</i>	<i>10th Middlesex</i>
<i>James Arciero</i>	<i>2nd Middlesex</i>
<i>Brian M. Ashe</i>	<i>2nd Hampden</i>
<i>Bruce J. Ayers</i>	<i>1st Norfolk</i>
<i>Joseph A. Boncore</i>	<i>First Suffolk and Middlesex</i>
<i>Michael D. Brady</i>	<i>Second Plymouth and Bristol</i>
<i>Daniel Cahill</i>	<i>10th Essex</i>
<i>Thomas J. Calter</i>	<i>12th Plymouth</i>
<i>James M. Cantwell</i>	<i>4th Plymouth</i>
<i>Gerard Cassidy</i>	<i>9th Plymouth</i>
<i>Tackey Chan</i>	<i>2nd Norfolk</i>
<i>Nick Collins</i>	<i>4th Suffolk</i>
<i>Edward F. Coppinger</i>	<i>10th Suffolk</i>
<i>Brendan P. Crighton</i>	<i>11th Essex</i>
<i>Claire D. Cronin</i>	<i>11th Plymouth</i>
<i>Daniel Cullinane</i>	<i>12th Suffolk</i>
<i>Josh S. Cutler</i>	<i>6th Plymouth</i>
<i>Michael S. Day</i>	<i>31st Middlesex</i>

<i>Marjorie C. Decker</i>	<i>25th Middlesex</i>
<i>Sal N. DiDomenico</i>	<i>Middlesex and Suffolk</i>
<i>Diana DiZoglio</i>	<i>14th Essex</i>
<i>Daniel M. Donahue</i>	<i>16th Worcester</i>
<i>William Driscoll</i>	<i>7th Norfolk</i>
<i>James J. Dwyer</i>	<i>30th Middlesex</i>
<i>Michael J. Finn</i>	<i>6th Hampden</i>
<i>Jennifer L. Flanagan</i>	<i>Worcester and Middlesex</i>
<i>Linda Dorcena Forry</i>	<i>First Suffolk</i>
<i>Sean Garballey</i>	<i>23rd Middlesex</i>
<i>Denise C. Garlick</i>	<i>13th Norfolk</i>
<i>Thomas A. Golden, Jr.</i>	<i>16th Middlesex</i>
<i>Carlos Gonzalez</i>	<i>10th Hampden</i>
<i>Kenneth I. Gordon</i>	<i>21st Middlesex</i>
<i>Danielle W. Gregoire</i>	<i>4th Middlesex</i>
<i>Stephan Hay</i>	<i>3rd Worcester</i>
<i>Paul R. Heroux</i>	<i>2nd Bristol</i>
<i>Natalie Higgins</i>	<i>4th Worcester</i>
<i>Russell E. Holmes</i>	<i>6th Suffolk</i>
<i>Kevin G. Honan</i>	<i>17th Suffolk</i>
<i>Daniel J. Hunt</i>	<i>13th Suffolk</i>
<i>Mary S. Keefe</i>	<i>15th Worcester</i>
<i>Jason M. Lewis</i>	<i>Fifth Middlesex</i>
<i>David Paul Linsky</i>	<i>5th Middlesex</i>
<i>Jay D. Livingstone</i>	<i>8th Suffolk</i>
<i>John J. Mahoney</i>	<i>13th Worcester</i>
<i>Paul W. Mark</i>	<i>2nd Berkshire</i>
<i>Christopher M. Markey</i>	<i>9th Bristol</i>
<i>Thomas M. McGee</i>	<i>Third Essex</i>
<i>Joseph W. McGonagle, Jr.</i>	<i>28th Middlesex</i>
<i>Paul McMurtry</i>	<i>11th Norfolk</i>
<i>Rady Mom</i>	<i>18th Middlesex</i>
<i>Frank A. Moran</i>	<i>17th Essex</i>
<i>James M. Murphy</i>	<i>4th Norfolk</i>
<i>Harold P. Naughton, Jr.</i>	<i>12th Worcester</i>
<i>Patrick M. O'Connor</i>	<i>Plymouth and Norfolk</i>
<i>Daniel J. Ryan</i>	<i>2nd Suffolk</i>
<i>Angelo M. Scaccia</i>	<i>14th Suffolk</i>
<i>Thomas M. Stanley</i>	<i>9th Middlesex</i>

<i>James E. Timilty</i>	<i>Bristol and Norfolk</i>
<i>Walter F. Timilty</i>	<i>Norfolk, Bristol and Plymouth</i>
<i>Paul Tucker</i>	<i>7th Essex</i>
<i>Steven Ultrino</i>	<i>33rd Middlesex</i>
<i>Aaron Vega</i>	<i>5th Hampden</i>
<i>John C. Velis</i>	<i>4th Hampden</i>
<i>RoseLee Vincent</i>	<i>16th Suffolk</i>
<i>Joseph F. Wagner</i>	<i>8th Hampden</i>
<i>Chris Walsh</i>	<i>6th Middlesex</i>

HOUSE No. 2821

By Mr. Lawn of Watertown, a petition (accompanied by bill, House, No. 2821) of John J. Lawn, Jr. and others for legislation to establish standards for medical gas piping systems. Consumer Protection and Professional Licensure.

The Commonwealth of Massachusetts

**In the One Hundred and Ninetieth General Court
(2017-2018)**

An Act to establish standards for medical gas piping systems.

Be it enacted by the Senate and House of Representatives in General Court assembled, and by the authority of the same, as follows:

1 The Massachusetts Board of Examiners of Plumbers and Gasfitters, under the terms of
2 Chapter 248 CMR, will be authorized to oversee and set standards for all work on medical gas
3 and vacuum piping systems located after the source valve in medical facilities. All regulations
4 promulgated subject to this section shall be consistent with National Fire Protection Association
5 healthcare facilities code (NFPA 99).

6