ASSEMBLY BILL NO. 257–ASSEMBLYWOMAN MARTINEZ

MARCH 12, 2021

Referred to Committee on Education

SUMMARY—Establishes provisions governing indoor air quality in public schools. (BDR 34-212)

FISCAL NOTE: Effect on Local Government: May have Fiscal Impact. Effect on the State: Yes.

EXPLANATION - Matter in *bolded italics* is new; matter between brackets [omitted material] is material to be omitted.

AN ACT relating to school property; requiring the board of trustees of a school district or the governing body of a charter school to assess and improve certain ventilation and filtration systems of a school to the extent that money is available; establishing requirements for such assessments and improvements; requiring certain personnel to complete an assessment report; requiring the board of trustees of a school district or the governing body of a charter school to prepare a report; requiring certain local educational agencies to include certain information in a plan to return to in-person instruction; and providing other matters properly relating thereto.

Legislative Counsel's Digest:

1 Section 6 of this bill requires the board of trustees of a school district or 23456789 governing body of a charter school, to the extent that money is available, to assess the status of and make improvements to the ventilation and filtration systems of a school and ensure that the systems are performing adequately and efficiently. Sections 7-10 of this bill set forth the requirements for qualified adjusting personnel or qualified testing personnel to assess and perform updates to: (1) a filtration system of a school; (2) the ventilation rates of a school; (3) the heating, ventilation and air conditioning system of a school; and (4) the carbon dioxide monitors in a school, respectively. Sections 7-10 generally require such systems, 10 rates and monitors to meet certain standards. Section 10.5 of this bill sets forth 11 requirements for an assessment of a school with a limited or no ventilation system. 12 Section 11 of this bill requires qualified adjusting personnel or qualified testing personnel to prepare an assessment report including certain information relating to the assessments conducted pursuant to sections 7-10.5. Section 12 of this bill 13 14 15 requires the board of trustees of a school district or the governing body of a charter 16 school to complete a report on the work performed by a qualified adjusting





17 personnel or qualified testing personnel pursuant to sections 7-10.5 and make the 18 report available to the Office of Energy and the public upon request. Existing 19 federal law requires a local educational agency that receives certain federal money 20 21 22 23 to develop a plan for the safe return to in-person instruction and continuity of services. (American Rescue Plan Act of 2021, Pub. L. No. 117-2, § 2001(i)) Section 13.5 of this bill requires a local educational agency to include the information contained in a report prepared pursuant to section 12 in such a plan.

THE PEOPLE OF THE STATE OF NEVADA. REPRESENTED IN SENATE AND ASSEMBLY, DO ENACT AS FOLLOWS:

Section 1. Chapter 393 of NRS is hereby amended by adding 1 2 thereto the provisions set forth as sections 2 to 13.5, inclusive, of 3 this act.

4 Sec. 2. As used in sections 2 to 13.5, inclusive, of this act, 5 unless the context otherwise requires, the words and terms defined 6 in sections 3 to 5, inclusive, of this act have the meanings ascribed 7 to them in those sections.

8 Sec. 3. "Apprenticeship program" means an apprenticeship 9 program recognized by the State Apprenticeship Council created by NRS 610.030. 10

11 Sec. 3.5. "Minimum efficiency reporting value" means the 12 minimum efficiency reporting value established by the American Society of Heating, Refrigerating and Air-Conditioning 13 14 Engineers, or its successor organization.

Sec. 4. "Qualified adjusting personnel" means a:

Technician certified to test, adjust and balance heating, 16 1. ventilation and air conditioning systems through a program 17 accredited by the Associated Air Balance Council, the National 18 19 Environmental Balancing Bureau or the Testing, Adjusting and 20 Balancing Bureau, or their successor organizations; or

21 Skilled and trained workforce under the supervision of a 2. 22 technician certified to test, adjust and balance heating, ventilation 23 and air conditioning systems through a program accredited by the Associated Air Balance Council, the National Environmental 24 25 Balancing Bureau or the Testing, Adjusting and Balancing 26 Bureau, or their successor organizations. 27

Sec. 4.5. "Qualified testing personnel" means:

28 1. A technician certified to test, adjust and balance heating, ventilation and air conditioning systems through a program 29 accredited by the Associated Air Balance Council, the National 30 31 Environmental Balancing Bureau or the Testing, Adjusting and 32 Balancing Bureau, or their successor organizations; or



15



2. A person certified to perform ventilation assessments of 1 2 heating, ventilation and air conditioning systems through a program accredited by the American National Standards Institute. 3

Sec. 5. "Skilled and trained workforce" means a workforce 4 5 not less than 60 percent of which is composed of graduates of an 6 apprenticeship program. **Sec. 5.5.** The Legislature hereby finds and declares that:

7

8

1. Studies have found that:

(a) Approximately 41 percent of the school districts in the 9 10 United States need to update or replace the heating, ventilation 11 and air conditioning systems in at least half of their schools;

12 (b) Most heating, ventilation and air conditioning systems are 13 *improperly installed*;

(c) Most classrooms fail to meet minimum standards for 14 15 ventilation rates:

(d) Many of the problems with heating, ventilation and air 16 conditioning systems are linked to the use of inadequately trained 17 personnel to install, test, adjust and balance heating, ventilation 18 19 and air conditioning systems; and

20 (e) Improved rates of ventilation and reduced carbon dioxide 21 concentrations can increase pupil performance.

22 Ventilation systems that are not properly installed, 2. 23 inadequate, inefficient or poorly maintained can significantly 24 increase costs to a public school.

25 3. Ventilation systems should operate as efficiently as 26 possible and inspections and repairs should be performed by 27 qualified personnel.

28 4. In addition to increasing the risk of infectious, airborne 29 diseases, inadequate ventilation systems in public schools 30 negatively impact the health and learning of pupils.

5. Improving indoor air quality in public schools may protect 31 32 the health of pupils and school staff, improve attendance, improve pupil performance, reduce the risk of infectious, airborne diseases 33 and save energy. 34

35 6. **Public schools should have functioning ventilation systems** 36 that meet or exceed recommended health and safety standards for 37 classrooms.

38 7. Consistent, statewide standards are necessary to protect the 39 health and safety of pupils, the ability of pupils to learn effectively and the health and safety of school staff in this State. 40

Sec. 6. 1. To the extent that money is available, the board 41 42 of trustees of a school district or the governing body of a charter 43 school shall ensure that each school in the school district or the 44 charter school, as applicable, is equipped with functional 45 ventilation systems that are tested, adjusted and, if necessary or





1 cost-effective, repaired, upgraded or replaced to increase 2 efficiency and performance.

2. The board of trustees of a school district or the governing body of a charter school that ensures a public school is equipped with functional ventilation systems pursuant to this section shall employ qualified adjusting personnel or qualified testing personnel to assess the status of and make any necessary improvements to the:

9 (a) Filtration system of the school in accordance with the 10 provisions of section 7 of this act;

11 (b) Ventilation rates of the school in accordance with the 12 provisions of section 8 of this act;

13 (c) Heating, ventilation and air conditioning system of the 14 school in accordance with the provisions of section 9 of this act; 15 and

16 (d) Carbon dioxide monitors at the school in accordance with 17 the provisions of section 10 of this act.

18 3. The board of trustees of a school district or the governing body of a charter school that ensures a public school is equipped 19 20 with functional ventilation systems pursuant to this section shall perform any work required to meet the minimum requirements for 21 22 ventilation and filtration established by sections 2 to 13.5, 23 inclusive, of this act, up to an estimated cost of not more than 24 \$200,000. The board of trustees of a school district or the 25 governing body of a charter school may perform any additional 26 recommended work that exceeds an estimated cost of \$200,000.

27 Sec. 7. In assessing a filtration system of a school pursuant 28 to section 6 of this act, qualified adjusting personnel or qualified 29 testing personnel, as applicable, shall:

30 1. Review the capacity and airflow of the filtration system to 31 determine the type of filters with the best minimum efficiency 32 reporting value based on industry standards that can be installed 33 without adversely impacting the filtration system;

2. Ensure that the filters used in the filtration system are of
the type determined pursuant to subsection 1 with the best possible
minimum efficiency reporting value;

37 3. Ensure that the filters are properly installed and replace or 38 upgrade the filters as needed;

39 4. If a filtration system uses ultraviolet germicidal irradiation 40 to disinfect air, ensure that the ultraviolet bulb is operating 41 properly and does not shine on the filters, and replace the 42 ultraviolet bulbs as needed;

43 5. If a filtration system uses an economizer, test and repair 44 the economizer dampers; and





Recommend any additional maintenance, replacements or 1 6. 2 upgrades to improve the overall performance of the filtration 3 system.

Sec. 8. 1. In assessing the ventilation rates of a school 4 5 pursuant to section 6 of this act, qualified adjusting personnel or 6 qualified testing personnel, as applicable, shall:

7 (a) Ensure that the ventilation rates in each room of the 8 facility that is routinely occupied meet the minimum requirements for ventilation rates set forth in the Uniform Mechanical Code; 9

10 (b) Calculate the required minimum outside air ventilation 11 rates for each room of the facility that is routinely occupied based 12 on the maximum anticipated rate of occupancy and the minimum 13 required ventilation rate per occupant in accordance with the 14 **Uniform Mechanical Code:**

15 (c) Ensure that the minimum outside air ventilation rates meet 16 the required minimum rate calculated pursuant to paragraph (b);

17 (d) If the minimum outside air ventilation rates do not meet 18 the required minimum rate calculated pursuant to paragraph (b):

19 (1) Determine whether additional ventilation can be 20 provided without adversely impacting the performance of the 21 filtration system or the environmental quality of the building; and

22 (2) If additional ventilation can be provided, adjust the 23 ventilation rates to meet the required minimum rate;

24 (e) If the minimum outside air ventilation rate cannot be met 25 after adjusting the ventilation rates pursuant to paragraph (d), 26 explain why the rate cannot be met; 27

(f) Conduct survey readings of the inlets and outlets to:

28 (1) Ensure that ventilation is reaching the served zone and 29 is adequately distributed;

30 (2) Ensure that the inlets and outlets are balanced to be 31 tolerated by the design of the filtration system;

32

(3) Document read values and deficiencies; and

(4) If the original values of the design of the filtration 33 system for inlets and outlets of the filtration system are not 34 35 available, document the available information and note the 36 unavailability of the original values;

(g) Ensure that there is a positive pressure differential between 37 the building and the outdoors, that the building is not overly 38 pressurized and that rooms designated for temporary occupation 39 40 by sick pupils or staff maintain a negative pressure differential or a pressure differential otherwise set forth by the applicable 41 42 industry standards;

43 (h) Ensure that the coil velocities and the coil and unit 44 discharge air temperatures maintain the desired indoor conditions 45 and avoid moisture carryover from the cooling coils;





1 (i) Ensure that the separation between the outdoor air intakes 2 and the exhaust discharge outlets is in accordance with the 3 <u>Uniform Mechanical Code;</u>

4 (j) Verify that the air handling unit is bringing in outdoor air 5 and removing exhaust air as intended by the design of the 6 filtration system;

7 (k) Measure the air volume for the exhaust fans and document
8 any discrepancies in volume between the measurements and the
9 original volume of the design of the filtration system;

10 (1) Verify that the coil condition, condensate drainage, air 11 temperature differentials of the cooling coils, operation of the heat 12 exchangers and drive assembly meet applicable industry 13 standards;

(m) Review the control sequences to verify that the systems will
 maintain the intended ventilation, temperature and humidity
 during school operation;

17 (n) Verify that daily flushes are scheduled in accordance with 18 the standards set forth by the American National Standards 19 Institute and the American Society of Heating, Refrigerating and 20 Air-Conditioning Engineers and any applicable local or state 21 guidance; and

(o) Ensure that the operation times and set points of the
 heating, ventilation and air conditioning system and exhaust fans
 are in accordance with any applicable guidance set forth by the
 American National Standards Institute and the American Society
 of Heating, Refrigerating and Air-Conditioning Engineers and
 any applicable local or state guidance.

28 2. Except as otherwise provided in subsection 3, if a demand 29 control ventilation system is installed at a school, qualified 30 adjusting personnel or qualified testing personnel, as applicable, 31 shall ensure that the set point for carbon dioxide is set to 800 parts 32 per million or less.

33 3. Qualified adjusting personnel, qualified testing personnel
34 or a licensed professional engineer shall disable a demand control
35 ventilation system installed at a school and configure the overall
36 ventilation system to meet the minimum requirements of sections 2
37 to 13.5, inclusive, of this act if:

(a) The demand control ventilation system does not maintain
an average daily maximum carbon dioxide concentration of less
than 1,100 parts per million;

(b) The board of trustees of the school district or governing
body of the charter school, as applicable, determines that a public
health crisis caused by an airborne illness is in effect; and

(c) Disabling the demand control ventilation system would not
 adversely affect the operation of the overall ventilation system,





1 *until the board of trustees or governing body determines that a* 2 *public health crisis caused by an airborne illness is no longer in*

3 effect.

Sec. 9. In assessing the heating, ventilation and air 4 5 conditioning system of a school pursuant to section 6 of this act, qualified adjusting personnel or qualified testing personnel, as 6 7 applicable, shall assess the overall performance of the heating, 8 ventilation and air conditioning system. If a heating, ventilation and air conditioning system is broken, fails to meet the minimum 9 requirements for ventilation established by sections 2 to 13.5. 10 inclusive, of this act or is otherwise unable to operate at the level 11 12 intended by the original design of the system, qualified adjusting personnel or qualified testing personnel, as applicable, shall 13 14 recommend any necessary repairs or maintenance. Any repairs or maintenance to the heating, ventilation and air conditioning 15 system must be performed by a skilled and trained workforce. 16

17 Sec. 10. In assessing the carbon dioxide monitors of a school 18 pursuant to section 6 of this act, qualified adjusting personnel or 19 qualified testing personnel, as applicable, shall ensure that each 20 classroom in the school is equipped with a carbon dioxide monitor 21 that:

Is hardwired or plugged in and mounted to the wall at least
 3 feet but not more than 6 feet above the floor and at least 5 feet
 away from any door or operable window;

25 2. Displays readings to appropriate personnel through a 26 display on the monitor or through an application on an Internet 27 website or a cellular phone;

28 3. Provides a visual notification, including, without 29 limitation, through an indicator light, electronic mail, text 30 message or an application on a cellular phone, when the 31 concentration of carbon dioxide in the room reaches 1,100 parts 32 per million or more;

4. Maintains a record of previous data that includes, without limitation, the maximum carbon dioxide concentration measured;

5. Has a range of 400 parts per million to 2,000 parts per million or more; and

6. Is certified by the manufacturer of the carbon dioxide
monitor to be accurate within 75 parts per million at a carbon
dioxide concentration of 1,000 parts per million and requires
calibration not more than once every 5 years.

41 Sec. 10.5. 1. If a public school has a limited or no 42 ventilation system, a qualified adjusting personnel or qualified 43 testing personnel, as applicable, shall document existing 44 conditions and provide a licensed professional engineer with any 45 information necessary for the licensed professional engineer to





1 make recommendations for upgrading or installing a ventilation 2 system.

3 2. Qualified adjusting personnel or qualified testing personnel that conducts an assessment of a public school with a 4 5 limited or no ventilation system shall determine whether carbon dioxide monitors that meet the requirements of section 10 of this 6 7 act are installed in each classroom of the school.

Sec. 11. 1. Qualified adjusting personnel or qualified 8 testing personnel, as applicable, shall prepare an assessment 9 10 report of any assessment performed in a school pursuant to 11 section 6 of this act. A licensed professional engineer shall: 12

(a) Review the assessment report and determine if any:

13 (1) Additional adjustments or repairs are necessary to meet 14 the minimum requirements for ventilation and filtration established by sections 2 to 13.5, inclusive, of this act; and 15

16 (2) Cost-effective upgrades for energy efficiency are 17 warranted; and

18 (b) Provide an estimated cost of any work required to meet the minimum requirements for ventilation and filtration established 19 20 by sections 2 to 13.5, inclusive, of this act, up to an estimated cost 21 of not more than \$200,000 and an estimated cost of any additional 22 recommended work up to an estimated cost of not more than 23 \$200.000.

The assessment report must include, without limitation: 2.

25 (a) The name and address of the person preparing the report 26 and the school where the assessments required pursuant to section 27 6 of this act were performed;

28 (b) For each piece of equipment assessed, the model number, 29 serial number, general condition and any additional information 30 that could be used to assess options for replacements, repairs or upgrades; 31

32 (c) Verification that the filters meet the best possible minimum 33 efficiency reporting values pursuant to subsection 2 of section 7 of this act or, if a filter does not meet the best possible minimum 34 35 efficiency reporting value, documentation of the current minimum 36 efficiency reporting value of the filter;

37 (d) Verification that the ventilation rates the meet requirements set forth in section 8 of this act or, if the ventilation 38 rates do not meet the requirements, an explanation of why the 39 40 ventilation rates do not meet the requirements;

(e) The measurements of air volume for the exhaust fans and 41 the documentation of any discrepancies in volume between the 42 43 measurements and the original volume of the design of the 44 filtration system prepared pursuant to paragraph (k) of subsection 45 1 of section 8 of this act;



24



1 (f) Verification that each assessment conducted pursuant to 2 sections 7 to 10.5, inclusive, of this act meets the requirements of 3 the applicable section;

4 (g) If the minimum outside air ventilation rate of a filtration 5 system cannot be met, the explanation of why the rate cannot be 6 met prepared pursuant to paragraph (e) of subsection 1 of section 7 8 of this act.

8 (h) If the original values of the design of the filtration system 9 for the inlets and outlets of the filtration system are not available 10 pursuant to paragraph (f) of subsection 1 of section 8 of this act, 11 documentation of the available information and a notation of the 12 unavailability of the original values;

(i) Documentation of any deficiencies within any system
assessed pursuant to section 6 of this act;

(j) Verification of the installation of carbon dioxide monitors
pursuant to section 10 of this act, including, without limitation,
the make and model of the carbon dioxide monitors;

18 (k) If applicable, documentation of the information prepared 19 pursuant to section 10.5 of this act for a school with a limited or 20 no ventilation system; and

(1) Recommendations for additional maintenance,
replacements or upgrades to improve the energy efficiency, safety
or performance of any system assessed pursuant to section 6 of
this act.

25 Sec. 12. 1. The board of trustees of a school district or the 26 governing body of a charter school that ensures a public school is 27 equipped with functional ventilation systems pursuant to section 6 28 of this act shall prepare a report on the status of the assessments 29 performed pursuant to section 6 of this act and any maintenance, 30 repairs or upgrades performed as a result of those assessments. 31 The report must include, without limitation:

(a) The name and address of the person preparing the report
and the school where the assessments required pursuant to section
6 of this act were performed;

(b) A description of the assessments performed pursuant to
section 6 of this act and any maintenance, repairs or upgrades
performed as a result of those assessments;

(c) Verification that the board of trustees of the school district
or governing body of the charter school, as applicable, has
complied with the requirements of section 2 to 13.5, inclusive, of
this act;

42 (d) Verification that the filters meet the best possible minimum 43 efficiency reporting values pursuant to subsection 2 of section 7 of 44 this act or, if a filter does not meet the best possible minimum





efficiency reporting value, documentation of the current minimum
 efficiency reporting value of the filter;

3 (e) Verification that the ventilation rates meet the 4 requirements set forth in section 8 of this act or, if the ventilation 5 rates do not meet the requirements, an explanation of why the 6 ventilation rates do not meet the requirements;

7 (f) The measurements of air volume for the exhaust fans and 8 the documentation of any discrepancies in volume between the 9 measurements and the original volume of the design of the 10 filtration system prepared pursuant to paragraph (k) of subsection 11 1 of section 8 of this act;

12 (g) Documentation of any deficiencies within any system 13 assessed pursuant to section 6 of this act;

(h) Documentation of the initial operating verifications and
adjustments, the final operating verifications and adjustments and
any adjustments or repairs performed;

(i) Verification of the installation of carbon dioxide monitors
pursuant to section 10 of this act, including, without limitation,
the make and model of the carbon dioxide monitors;

20 (j) If applicable, documentation of the information prepared 21 pursuant to section 10.5 of this act for a school with a limited or 22 no ventilation system;

(k) Verification that all work has been performed by qualified
adjusting personnel or qualified testing personnel or a skilled and
trained workforce, as appropriate, which may include, without
limitation, the provision of the name and, if applicable,
certification number of any contractor, qualified adjusting
personnel or qualified testing personnel.

29 2. The board of trustees of a school district or the governing 30 body of a charter school shall maintain the report prepared 31 pursuant to subsection 1 for at least 5 years and make a copy of 32 the report available to the Office of Energy or any member of the 33 public upon request during the time in which the report is 34 maintained.

35 Sec. 13. (Deleted by amendment.)

36 Sec. 13.5. A local educational agency, as defined in 20 37 U.S.C. § 7801(30)(A), that develops a plan for the safe return to 38 in-person instruction and continuity of services pursuant to 39 section 2001(i) of the American Rescue Plan Act of 2021, Public 40 Law 117-2, shall include in the plan the information contained in 41 a report prepared pursuant to section 12 of this act.

42 **Sec. 14.** This act becomes effective on July 1, 2021, and 43 expires by limitation on June 30, 2023.





– 10 –